


All pipe fittings in this area MUST be Copper, brass, bronze or Steel and must extend a minimum of 12" above the "T" before connecting to CPVC or PEX

**BRONZE or STAINLESS STEEL**  
Circulating Pump  
mounted vertical (Can be Installed in either Line)  
Wired to "DHW Pump 230 Vac" Terminal strip in system electrical box

All copper piping must be the same size as the fittings on the Hydro-Temp system. Under sizing this piping will reduce the gpm flow and can damage the unit and void the warranty. If 1" copper is used it must be reduced to 3/4" as close to the tank as possible.  
Note: on long piping runs the copper piping may need to be "upsized" to lower the pressure drop of the circuit.

THIS DRAWING, THE DESIGN AND DEVELOPMENTS ARE THE PROPERTY OF AND ARE NOT TO BE USED OR REPRODUCED IN ANY WAY WITHOUT WRITTEN CONSENT OF HYDRO-TEMP LTD.



DWG. Title	DATE	DWG. NO.	REV
Dual Hot water tanks (series)	06/12/2014	H005672B	0
	Edit Date		
	11/05/2015		